


Grid Disturbance in Mumbai

Date:25/11/2010

Reliance Infrastructure Ltd.


Transmission Network for Mumbai



Grid Disturbance: 18/11/2010

@ 17:39:16 Date:18/11/2010

Frequency: 49.68 Hz




DTPS Generation: 493 MW



119 MW



183 MW




@ 17:39:17


Trombay-Salsette -1 Tripped

Heavy jerk experienced with a voltage dip

Subsequently Trombay-Salsette -2 Tripped




**MSETCL Borivali ICT Trips. TPC Boivali fed by Boisar and DTPS
Boisar Interconnection Trips on overloading.
Frequency begins to deep. Load shedding at Rinfra initiated at 48 Hz**




**Power flow Reversed. Aarey Borivali now exporting power
Frequency begins to dip. Load shedding at RInfra initiated at 48 Hz (400MW + load Sheded)**

Reverse flow from REL to TPC 284 MW Export




| Object Na | Object Descript | Aspect | Propert | Log Na | Current Valu | Low Ra | High R | Ruler Time | Ruler Value | Mean V | Min Val | Max Val |
|-----------|-----------------|-----------|----------|--------|--------------|--------|--------|------------------------|-------------|--------|---------|---------|
| ActPow | DGT1 ACTIVE PO | Control | Value.V | Log1 | 248.28 | -1.00 | 350. | 11/18/2010 05:45:13 PM | 255.59 | 200.60 | 4.51 | 264.64 |
| ActPow | DGT2 ACTIVE PO | Control | Value.V | Log1 | 245.62 | -1.00 | 371. | 11/18/2010 05:45:13 PM | 244.23 | 229.93 | 0.00 | 272.01 |
| Bus1freq | BUS 1 FREQUENC | Function | In.IOVal | Log1 | 50.04 | 44.0 | 55.0 | 11/18/2010 05:45:13 PM | 49.68 | 49.20 | 45.00 | 52.27 |
| Dahanu_Ad | IMP/EXP MVAR | Applicati | gIMP_E | Log1 | -30.94 | -150. | 100. | | | -4.26 | -49.35 | 44.92 |
| Voltage | BUS 1 VOLTAGE | Control | Value.V | Log1 | 222.44 | 0.00 | 350. | 11/18/2010 05:45:13 PM | 216.79 | 216.86 | 139.80 | 234.50 |
| IMP_EXP | IMP/EXP | Function | In.Value | Log1 | -295.74 | -550. | 550. | 11/18/2010 05:45:13 PM | 284.11 | 132.80 | -184.73 | 284.50 |



**DTPS and RInfra-T forms an independent Island. DTPS feeding balance load of RInfra
Frequency Shoots above 52 Hz.**

Frequency reached 52.67 Hz




Navigation and status bar: 45 Minutes | 11/18/2010 5:45:05 PM

| Object Na | Object Descript | Aspect | Propert | Log Na | Current Valu | Low Ra | High R | Ruler Time | Ruler Value | Mean V | Min Val | Max Val |
|-----------|-----------------|-----------|----------|--------|--------------|--------|--------|------------------------|-------------|--------|---------|---------|
| ActPow | DGT1 ACTIVE PO | Control | Value.V | Log1 | 248.66 | -1.00 | 350. | 11/18/2010 05:45:24 PM | 178.42 | 200.60 | 4.51 | 264.64 |
| ActPow | DGT2 ACTIVE PO | Control | Value.V | Log1 | 244.70 | -1.00 | 371. | 11/18/2010 05:45:24 PM | 152.07 | 229.93 | 0.00 | 272.01 |
| Bus1freq | BUS 1 FREQUENC | Function | In.IOVal | Log1 | 49.91 | 44.0 | 55.0 | 11/18/2010 05:45:24 PM | 52.27 | 49.20 | 45.00 | 52.27 |
| Dahanu_Ad | IMP/EXP MVAR | Applicati | gIMP_E | Log1 | -34.97 | -150. | 100. | | | -4.26 | -49.35 | 44.92 |
| Voltage | BUS 1 VOLTAGE | Control | Value.V | Log1 | 222.12 | 0.00 | 350. | 11/18/2010 05:45:24 PM | 234.43 | 216.86 | 139.80 | 234.50 |
| IMP_EXP | IMP/EXP | Function | In.Value | Log1 | -297.26 | -550. | 550. | 11/18/2010 05:45:24 PM | 1.01 | 132.80 | -184.73 | 284.50 |

**DTPS turbine Tripped on Over speed-
Mechanical Operation**

DTPS Unit 1 trips



**Major parts of Suburbs of Mumbai Dark.
Salsette Bus Coupler Closed. Restoration Operation begins**

220 kV Network Line's Restoration


- ❑ 220 KV Bus at Aarey was charged from TPC Borivali at 17:55 Hrs
- ❑ Start Up power was extended to DTGS @ 18:04 Hrs from 220kv MSETCL Boisar – Dahanu.
- ❑ Unit -2 was synchronized @ 20:12 Hrs
- ❑ Unit -1 was synchronized @ 21:18 Hrs

Distribution Restoration


- ❑ Area-wise Restoration of R-Infra Distribution Loads carried out in phase manner
- ❑ Part of Mira, Dahisar and Ghodbunder under rotational load shedding (40 MW approx.) to avoid Overloading of PGCIL (Boisar) Lines as per the instructions from MSLDC.

Incidence 21/11/10

Scenario 1 – Pre Disturbance Scenario



Scenario 2 – During Disturbance Scenario



Key Observations

1. Tripping of 220 kV Lines


- ❑ Single Line tripping due to transients
- ❑ Single Line tripping due to faults
- ❑ Double circuit Line tripping
- ❑ Double circuit line tripping due to tower collapse

Such occurrences should not result in total grid failure


System redundancy lost

Network fragile

2. Redefining Islanding Scheme




Islanding did not fail. However, the scenario is changing.....



Mumbai Islanding system needs to be relooked


Core technical team needs to be formulated

3. Mumbai power scenario




Mumbai power scenario Cond...

- Demand to continue with increasing trend YOY in the future
 - Demand-supply gap to only increase from hereon
 - Power has to be brought from outside
 - *Multiple connectivities – need of the hour!*



**Existing capacity of transmission lines to bring power from outside Mumbai : 1000 MW.
Peak capacity usage recorded :800+ MW**



Critical Requirement: 400 kV EHV Sub-Stations for Mumbai

Geographical Constraints

- Mumbai surrounded with Forests on one end and sea on the other sides
- No corridor available for Overhead transmission lines for bringing power



Need of Multiple Grid Connectivity

(Addressed in Various forums)

Addressing to immediate Solutions

Major Lines for Bulk power (Schemes proposed)

- **Islanding scheme to be revisited with Expert technical team**
- **Coordination with SLDC**
- **In-Principle Clearance from MERC for Bulk Power Schemes to Mumbai to be granted on priority**
- **Address the RoW issues in the State Co-ordination Forum and State Advisory Committee**

Thank You

25th November' 2010